

S
P
E
C
I
F
I
C
A
T
I
O
N

National
Air
Filtration
Association



National
Air
Filtration
Association
Recommended Practice

Firing Ranges

TRAINING
EDUCATION
CERTIFICATION

NAFA Guidelines Committee

Chair

Phillip Masters, CAFS

R. P. Fedder Corporation
740 Driving Park Avenue
Rochester, NY 14613
Phone: 585-288-1600 x 117
800-288-1660
Fax: 585-288-2481
Email: philm@rpfedder.com
Web: www.rpfedder.com

National Air Filtration Association

PO Box 68639
Virginia Beach, VA 23471
Phone: 757-313-7400
Fax: 757- 497-1895
Email: nafa@nafahq.org
Web: www.nafahq.org

Vice Chair

Stevan Brown, CAFS

TEX-AIR Filters/Air Relief Technologies
5757 E. Rosedale
Fort Worth, TX 76112
817-261-3791
Fax: 817-496-3430
Email: sbccs@msn.com
Web: www.allergyclean.com

Committee Members:

Joseph Benoit, CAFS
Filtration Group, Inc.

Stevan Brown, CAFS
TEX-AIR Filters/Air Relief Technologies

Carol Christensen, CAFS
The Filter Man, Ltd.

Kevin Delahunt, CAFS
B.G.E. Service & Supply Ltd.

Leonard Duello, CAFS
Ahlstrom Air Media

Alisa Edmunds, CAFS
Filtration Group, Inc.

Dave Hurd, CAFS
PlymoVent Canada Inc.

Rupert Langston, CAFS
Air Flow Technology, Inc.

Paula Levasseur, CAFS
Cameron Great Lakes, Inc.

William Matkins
Aeolus Corporation

Phil Maybee, CAFS
The Filter Man, Ltd.

Bill Palmer
AeroMed, Inc.

Bill Patterson, CAFS
Dave Downing & Associates

Thomas Riddell, CAFS
Air Filter Sales & Service

Purpose 2

Scope 2

Background.. 2

 Potential health issues from firing ranges..... 2

 Early signs and symptoms of lead poisoning 3

 Areas of potential lead concentration within the range..... 3

Ventilating an Indoor Firing Range..... 3

System Designs 5

 Single Pass System 5

 Recirculating System 5

Filtration Requirements..... 6

Framing Systems... 6

Molecular Filtration. 6

System Startup and Maintenance 7

 NAFA Recommended Practice 7

 Filter Service Recommendations 7

 Filter Evaluation (gauges) 7

Precautions and Employee Protection 7

Filter Disposal 7

Glossary..... 8

Bibliography 8

Purpose

This best recommended practice establishes air filtration guidelines for the removal of airborne contaminants for the protection of employees and participants in indoor firing ranges.

Scope

To identify air quality issues associated with indoor firing ranges. Also, to provide air filtration component selection, application, and maintenance guidelines for those involved in the design of indoor firing ranges.

Background

Exposure to lead and fumes from a firing range can present a potential health risk to shooters as well as the employees of a firing range. Protecting the health and welfare of occupants in a firing range, while minimizing the environmental contamination from lead exposures, is an important element in the operational procedures for a firing range. Filtration plays an integral role in reducing the risk of toxic exposure in indoor shooting facilities.

Potential Health issues from firing ranges

The firing of bullets from firearms creates a significant quantity of pollutants that are potentially toxic to humans. The Occupational Health and Safety Administration (OSHA) has established a standard for lead exposure to employees, CR 1910.1025. The Permissible Exposure Limit (PEL) for workers is 50 micrograms per cubic meter of air of exposure averaged over an 8 hour period.

Lead adversely affects the body by poisoning the blood. Lead poisoning is caused by lead oxide dust which is generated from the friction of lead bullets ejecting from the barrels of the guns used in the range. Metallic lead dust is not the primary culprit as the actual metals are heavy enough that the body can process and clean it from the system. Several fumes, created by the firing process, are harmful when introduced through the respiratory system. Lead oxide is the white powdery substance that is oxidation of the lead itself and it is toxic by inhalation, absorption through the skin, or ingestion.

Early signs and symptoms of lead poisoning

Fatigue	Headaches	Uneasy Stomach
Sleeplessness	Nervousness	Poor Appetite
Metallic "Taste"	Irritability	Reproductive Problems

Each individual reacts differently to lead exposure. One of the most common pathways of lead poisoning occurs from hand to mouth ingestion sources. This is the reason it is not advisable to allow smoking or consumption of food and/or beverages in, or around the firing range.

Areas of potential lead concentration within the range

There are three key areas within an indoor firing range where lead is most concentrated and potentially high risk. These are the Shooters Station, the area approximately 15 feet down range from the shooters station, and the target area. Each of these areas has their own unique sets of circumstances that create potential risks. See *Typical Firing Range Diagram on page 5*.

Shooters Station

This is the point of highest airborne concentration, due to the firing of the guns and the barrel discharge. Each shot fired releases a small quantity of harmful dusts and gases which should not be allowed into the breathing zones of the shooters or other occupants of the range.

Area 15 feet down Range

This is the region that the EPA found greater than 90% of the "heavier dusts" settle from the air stream. This area becomes extremely contaminated from this waste dust and should not be entered without the proper protective gear, per OSHA guideline CFR 1910.134. The primary exposure risk is contact from this region.

Target Area

It is in the target area where the fragmentation of lead from bullets is highest. There are a few designs for capturing bullets in target areas. While each has advantages and disadvantages, the fragmentation of lead means the lead oxide develops at very rapid rates and is likely a hazard through contact and inhalation. This area should not be entered without OSHA regulated protective gear.

Ventilating an Indoor Firing Range

Types of firing ranges may dictate system and equipment design for optimum use within the standard range parameters, however ventilation is a critical part to the reduction of lead exposure. Once a system is built it should provide effective air movement toward the target area away from the shooters stations and the gallery areas of the facility. Additionally, a system must be maintained properly and kept free of obstructions that

may alter or interfere with the ventilation patterns designed to control the airflow. It is critically important that the actual range ventilation be isolated from any of the other building HVAC systems to prevent any potential cross contamination of non-protected areas. Exhaust air should be established so that it does not re-entrain into the make-up air intakes.


There are several designs used currently within firing ranges for ventilation control of the dust and fumes of the firearm discharging. The most common has been to supply air behind the shooter toward the target area in an attempt to create a "laminar flow" of air to wash the contaminants down range. Maintaining a design velocity between 50 to 100 feet per minute (fpm) is recommended. Higher airflows may create a circular flow of air starting downstream of the shooter, allowing contaminated air into the breathing zone. In addition higher velocities may create optical distortion of movement of the target itself. Another design being used by some government facilities introduces make-up air at each shooters station in small quantities to move the air down range.

While there are debates over the airflow rates, one clear agreed upon criteria is that the air should be visibly moving all smoke and fumes down range away from the shooters' stations and gallery. This is accomplished by creating a slightly negative pressure down the range. Air will seek the negative pressure release point. OSHA research has verified that the heaviest concentration of fallout dust in a range is an area roughly 15 feet down range from the shooter.

It is imperative that the breathing zones of the shooter stations be supplied clean air for the persons occupying the range. This means that any of the contaminants must be moved down range or filtered from the air if the air is re-circulated through the HVAC system.

Breathing Zone for Shooters

Most engineers use a system that will provide proper airflow across the breathing zone of range occupants, introduce sufficient levels of fresh outside air, maintain a negative range pressure differential with respect to other areas of the building, and remove offending contaminants through the use of air filtration. Air shall be introduced in a horizontal laminar pattern if possible.



The breathing zone is different for these two shooters.

Most firing ranges are for pistol use and the shooter shoots primarily from a standing position. The breathing zone is typically 1 to 7 feet from the floor.

If the firing range accommodates kneeling or prone positions, then the breathing zone for these positions are much closer to the floor (1 to 4 feet).

Supply air should always be introduced behind the shooting positions. The system should be capable of accommodating all planned shooting positions.

System Designs


Single Pass System

One of the simplest of system designs is for air to make one pass through the range. This would use 100% outside air drawn into the area behind the shooters and pass through the range and exhaust out the opposite end. While this is simple in design, it is very costly due to the cooling or heating of 100% outside air.

Re-circulating System

This system allows for most of the contaminated air to be filtered and re-introduced into the space. Some exhaust to atmosphere is still necessary to maintain the negative pressure down range. This exhaust air must be filtered in accordance with the United States Environmental Protection Agency (EPA) requirements. A make-up air intake is required to maintain air balance in this design. Drawing in clean, outside air will also help provide the dilution required to maintain air quality. As a rule of thumb, the supply air should be 10% less than the exhaust air.

Typical Firing Range Diagram



Filtration Requirements

There are two concerns that should be dealt with when providing the filtration in a firing range. The first is that the make-up air must be filtered to protect the HVAC equipment from outside contaminants. The second is for the removal of the hazardous contaminants that are generated by the firearms when exhausting or re-circulating the air from within the facility.

Make-up air should be filtered with a Minimum Efficiency Reporting Value, (MERV) 14 filter in accordance with ASHRAE (American Society of Heating, Refrigeration and Air-conditioning Engineers) Standard 52.2. These should be sized to provide adequate efficiency and proper sealing mechanisms for installation in the HVAC system. The filter face velocities should be designed at 400 fpm with pressure drop indicators installed to help determine filter change-out points.

Exhaust or re-circulated air must be filtered at the point of removal with a minimum of 99.97% High Efficiency Particulate Air (HEPA) filter, per the Institute of Environmental Sciences and Technology (IEST) recommended practice for HEPA/ULPA filters (IEST RP-CC001). All HEPA filters should be accompanied by a letter of certification or a label documenting that each filter has met the test requirements. The airflows should be designed at the manufacturers recommended face velocity, usually 250 fpm. Pressure drop measuring devices should be installed on all HEPA filter sections for monitoring filter life cycles.

It is recommended that HEPA filters be pre-filtered with a minimum of MERV 14 filters to provide an extended life cycle of the HEPA filters. A MERV 7 pre-filter should also be considered to extend the life of the MERV 14 filter. Pressure drop measuring devices should be installed on all filter sections for filter maintenance.

Framing Systems

Framing systems shall be specifically designed and tested for HEPA filters, so as to eliminate leakage or penetration of air around the filter. A proper filter gasket consisting of closed cell foam rubber is critically important to eliminate air bypass. All housings and components should be leak free up to 6.0" water gage (w.g.).

Molecular Filtration

Traces of carbon monoxide, barium oxide, nitrogen dioxide, nitrogen tetroxide and oxides of sulfur may also be found in an indoor range. While the make-up air will provide dilution of the known gaseous contaminants created in the shooting range it is advisable to provide for molecular filtration whenever the air is being re-circulated. This filter section can be installed in the HVAC portion of the shooting range system. Makeup air ratio of 30% is recommended to prevent the buildup of oxides of nitrogen and carbon.

System Startup and Maintenance

NAFA Recommended Practice

The HEPA filters should be leak-tested, in-situ, using the cold dioctylphthalate (DOP) (or accepted alternative aerosol) method prior to initial startup and after replacement. Testing must be done by a trained certifier. A certificate of this test shall be kept by the owner.

Filter Service Recommendations

Manufacturers' recommendations for filter changing procedure will be followed when servicing air filters. Use of protective gear, such as gloves and dust masks, should be used when handling used filters removed from an HVAC system.

Filter Evaluation (gauges)

To ensure that filters are operating properly and that the maximum life of each stage is utilized, Magnehelic gauges should be used to determine the differential pressure drop across the filter bank. An optimum installation includes a filter gauge for each stage of filters. Multiple gauges allow immediate evaluation of an individual bank so corrective measures may be taken as soon as possible, i.e. a sudden drop in gauge reading may indicate a filter failure. A single gauge with gauge cocks designed to isolate each filter stage is also acceptable.

HVAC system velocities can vary widely based upon the designer (typically from 350 to 500 fpm). Filter manufacturers publish maximum recommended final pressure drop values to prevent degradation of the filter. In a firing range system an additional level of security is recommended. NAFA recommends changing the air filter when the initial pressure drop doubles, i.e. initial pressure drop is .35" w.g. x 2 = .70" final change-out.

Precautions and Employee Protection

Lead Oxide dust should never be handled with bare skin contact. The lead dust clean-up in the range should never be swept as a cleaning method, this will aerosolize the dusts. Employees changing filters should wear protective equipment including gloves, outer wear, mask and goggles. The OSHA (CFR 1910.134) guidelines or the respective states or regional guidelines should be followed for protective gear.

Filter Disposal

Used (non-hazardous) filters will be wrapped in two layers of (six) 6 mil poly and sealed with duct tape. Potentially hazardous or contaminated filters shall be disposed of in accordance with all local, state and federal regulations.

Glossary

The following terms and abbreviations may be used within this document

ASHRAE.....American Society of Heating, Refrigerating and Air-conditioning Engineers
CAFS... ..Certified Air Filter Specialist
CFM..... ..Cubic feet per minute; a volumetric measurement used to size fans and duct work.
Cold DOP
Test MethodSee NAFA Guide to air Filtration
DOP..... ..Diocetylphthalate
EPAEnvironmental Protection Agency; United States
FPM..... ..Feet per minute; a measurement of air velocity used in calculating cfm requirements.
HEPA... ..High Efficiency Particulate Air
HVACHeating, Ventilation, and Air-conditioning
IESTInstitute of Environmental Sciences and Technology
In-situ... ..In place; as in, "to test *while installed in system*"
MERV.. ..Minimum Efficiency Reporting Value (ASHRAE Standard 52.2)
NAFA... ..National Air Filtration Association
OSHA.. ..Occupational Safety and Health Administration; United States
PEL..... ..Permissible Exposure Limit; standard level of exposure levels set by government regulations.

Bibliography; Sources and References

Controlling Airborne Lead in Indoor Firing Ranges, Environmental Hygienist, July 1990

Controlling Lead Exposures in the Workplace, the Lead Industries Association, Inc.

Firing Range Design, Cambridge Filter Corporation

Firing Ranges, The Airborne Lead Dust Hazard Shooters Guide, and Firing Ranges, The Airborne Lead Dust Hazard, Employers Guide, Texas Department of Health

Indoor Firing Range Indoor Air Cleaning Systems, American Air Filter

Indoor Firing Range Ventilation System, Brian O'Rourke, HPAC, October, 1992

Lead Exposure and Design Considerations for Indoor Firing Ranges, NIOSH 75-130

Lead Exposure at an Indoor Firing Range, United States Department of Commerce

Lead Exposure at an Indoor Firing Range, T.L. Anania, J.B. Lucas, J.A. Seata, DHEW, National Institute of Occupational Safety and Health, Publications 74-100 and 76-130

Lead on the Range, Boston University School of Public Health

Indoor Pistol and Small Bore Rifle Range Ventilation, American Conference of Governmental Industrial Hygienists, 1978

Indoor Shooting Range, Boyd Morgenthaler, P.E., David F. Shumway, P.E., ASHRAE Journal, December 2002

Occupational Lead Poisoning, Kevin C. Staudinger, M.D. M.P.H, Victor S. Roth, M.D., M.P.H., American Family Physician, February 15, 1998

Occupational Exposure to Lead: Final Standard, Federal Regulation 43 (220), US Occupational Safety & Health Administration, 1978

On Target with Camfil Farr, Camfil Farr, 1997

OSHA Lead Standard (29 CFR 1910.1025)

Other NAFA Publications

NAFA Guide to Air Filtration



Air filtration is one of the most important considerations involving the design, installation and maintenance of HVAC systems, yet is one of the least understood concepts in the HVAC industry. Thus, the need for the NAFA Guide to Air Filtration, which is the most informative and comprehensive manual ever published in the HVAC Industry.

Now in its 3rd edition, the NAFA Guide to Air Filtration covers principles of air filtration, applications of all types of air filter products, filter testing methods, indoor air quality, filter owning and operating costs, plus much, much more. Over 200 pages with numerous tables, photos and illustrations help to educate the reader on the mechanics and elements of air filtration.

The NAFA Guide to Air Filtration is required reading for anyone wishing to become a NAFA Certified Air Filter Specialist. The certification examination is based on material in the manual.

It is also suggested reading for anyone involved in the design, installation, or maintenance of HVAC systems. For a copy of the NAFA Guide to Air Filtration, contact a NAFA member in your area or the NAFA home office.

Member Cost: \$49.00; Nonmember Cost: \$79.00

Installation, Operation & Maintenance of Air Filtration Systems

This manual is designed to serve as a guide for those involved in the installation, operation, and maintenance (IOM) of air filtration systems. Over 100 pages with nearly 50 illustrations highlight the universal characteristics and the important procedures involved in the IOM of air filtration systems.



Ideal for both teaching the basics to individuals just starting out in the field, as well as serving as a reference guide for experienced personnel, this manual is a must for anyone involved in the industry. The NAFA IOM Manual, 2nd Edition is required reading for the NAFA Certified Technician (NCT) program.

Member Cost: \$36.00; Nonmember Cost: \$48.00

NAFA Programs

NAFA Certified Air Filter Specialist Program



The CAFS program distinguishes those professionals who have demonstrated a thorough, up-to-date understanding of air filtration technology and a high level of professionalism.

In order to become certified, air filtration professionals must pass an extensive examination on the principles, methods and applications of air filtration, based on the text, NAFA Guide to Air Filtration, 3rd Ed. Candidates for certification are also subject to compliance with the NAFA Code of Ethics.

Certification is renewable on an annual basis pending successful completion of continued education requirements in order to demonstrate current and continued expertise.

When purchasing products or services from a Certified Air Filter Specialist, customers are assured that their particular requirements and needs will be addressed by a knowledgeable professional.

NAFA Certified Technician Program

The NAFA Certified Technician Program (NCT) is a certification program for technicians involved in the installation, operation, and maintenance of commercial air filtration systems. Originally created for NAFA members, the program has been redesigned to suit the needs of facility managers, building owners, HVAC service contractors, and those who employ technicians in the HVAC industry.



In order to certify technicians, candidates must pass an exam administered by any NAFA Certified Air Filtration Specialist (CAFS). Training sessions with a CAFS, self-study, and seminars, prepare candidates for the exam, which is an open book test with NAFA's Installation, Operation, and Maintenance of Air Filtration Systems Manual (IOM Manual).

Being NAFA certified provides education for individuals in the service of air filtration systems, recognizes the knowledge and expertise of technicians, and develops formalized structure for ongoing education of maintenance staff.

NAFA Product Certification



One of NAFA's latest initiatives is the development of the NAFA Product Certification Program. The program is designed to verify the performance of various air filter products as advertised by their manufacturers.

Participation by manufacturers in the program is voluntary. As the program gets underway, it is expected that most major manufacturers will submit products for certification. The public may access the NAFA website to see which products have been certified through the program.